


1 FIRST FLOOR LIGHTING PLAN



- NOTES:
1. ALL ELECTRICAL DEVICES SHOWN ARE EXISTING TO REMAIN, UNLESS OTHERWISE NOTED "NEW" ON PLANS AND/OR IN LIGHTING FIXTURE SCHEDULE. CONTRACTOR TO PROVIDE AND INSTALL NEW FACE PLATES FOR ALL NEW AND EXISTING ELECTRICAL DEVICES; COORDINATE FINISHES WITH THE ARCHITECT.
 2. REUSE EXISTING WIRING TO EXISTING ELECTRICAL DEVICES TO REMAIN.
 3. REUSE EXISTING WIRING TO PROPOSED LIGHTING FIXTURES FROM EXISTING AND NEW LIGHT SWITCHES.
 4. INSTALL TWO (2) NEW MOLDED-CASE CIRCUIT BREAKERS, 240VAC, 20A, 1-POLE IN EXISTING APARTMENT PANELBOARD SPACES 14 & 16; MATCH EXISTING KALC RATING.
 5. REPLACE EXISTING 200A, 3-PHASE, 208/120VAC PANELBOARD AS SHOWN, REUSE EXISTING WIRING AND CONDUITS. INSTALL A NEW CUSTOMER METERING, SIMILAR TO E-MOND-MON MODEL NUMBER E50-208200-R01KIT-05. REFER TO PANELBOARD SCHEDULE FOR MORE INFORMATION.
 6. INSTALL A NEW CUSTOMER METERING, SIMILAR TO E-MOND-MON MODEL NUMBER E50-208200-R01KIT-05 TO MONITOR INCOMING ELECTRICAL POWER TO THE PANELBOARD.
 7. INSTALL ONE (1) NEW MOLDED-CASE CIRCUIT BREAKER, 240VAC, 20A, 1-POLE IN EXISTING PP-HR IN SPACE 14; MATCH EXISTING KALC RATING.



GRANT ENGINEERING CONSULTANTS, LLC
99 CARTERET STREET
GLEN RIDGE, NJ 07028
T: 732.740.7889
F: 973.566.0123
WWW.GRANTENGINEERING.ORG

FRANK GRANT, PE, NJ LIC. NO. 24630424800

RAMAPO COLLEGE OF NEW JERSEY "BUCKEYE" RESIDENCE INTERIOR RENOVATION 505 RAMAPO VALLEY ROAD, MAHWAH, NEW JERSEY

1	12/02/2014
REVISION	DATE
DRAWING TITLE	

FIRST FLOOR LIGHTING
PLAN

DATE
11/12/2014

SCALE
AS NOTED

DRAWN
MO

CHECKED
JTG

DRAWING #

E-100

SHEET _____ of _____
DCA PROJECT # 8214-14