

ADDENDUM NO. 02
Dated January 16, 2015

THE PURPOSE OF THIS ADDENDUM IS TO CHANGE THE FOLLOWING ITEMS:

To revise and add project specifications, drawings and clarifications to the bid documents.

CLARIFICATIONS:

1. Contractor to furnish and install a complete fire sprinkler system that meets current code utilizing existing heads and piping where applicable. It is not the intent of this contract to replace the entire existing fire sprinkler system with new.
2. On A-003 detail 4, frame elevations note details for head and jamb incorrectly shown. Shown as #9 and #10, should be shown as #5 and #6.
3. On A-004 RCP legend, exit signs and emergency battery unit with 2 lights, "Not in contract", these items ARE in contract.
4. On drawing FP-001, note 15, contractor to perform flow test to verify system pressure at site prior to proposal of submittals. See attached Ramapo College Annual Fire Hydrant Inspection Report and Campus Map with Fire Hydrant Locations. The hydrant servicing Buckeye is H-23.
5. Contractor to inspect and repair all existing insulation on piping to fan coil units throughout the buildings.
6. See drawing A-006 for plumbing/fixture equipment schedule.
7. On drawing A-006 elevation 1 shows the kitchen area. It notes ¼" backsplash. Backsplash to be the same material as the countertop.
8. On drawing A-006 elevation 2 shows the bathroom with 4" backsplash which gets an array vanity top. Backsplash to be the same material as the countertop.

CHANGES TO THE DRAWINGS:

1. **Replace** drawing A-000 and A-004. Revisions are clouded and denoted as noted on drawing. Change dated 1/16/15.
2. **Replace** drawing P-001. Revisions are clouded and denoted as noted on drawing. Change dated 1/16/15.
3. **Add** drawings FP-001, FP-100, FP-101. New drawings dated 1/16/15.

ALL DRAWINGS NOT LISTED ARE UNCHANGED FROM ADDENDUM #1

Attachments:

Ramapo College of New Jersey
College Park Apartments Phase 1 Interior Renovations – Buckeye Renovation
RCNJ Project # 2014-01-02C.1

DRAWINGS:

A-000 - Cover Sheet
A-004 - Enlarged Plans and Reflected Ceiling Plans
P-001 - Plumbing Plans and Diagrams
FP-001 - Fire Protection system notes and specifications
FP-100 - Crawlspace and attic fire protection plans
FP-101 - 1st and 2nd floor fire protection plans

INFORMATION:

Ramapo College Annual Fire Hydrant Inspection – Dated 11/06/15
Ramapo College Map with Fire Hydrant Locations. (Hydrant for Buckeye is H-23)

END OF BID ADDENDUM NO. 02