

THIRD FLOOR POWER PLAN
SCALE: 1/4"=1'-0"

POWER PLAN NOTES:


- WHERE EXISTING WIRING AND CIRCUITRY WHICH IS TO REMAIN IS LEFT EXPOSED BY DEMOLITION AND REMOVAL OF PARTITION AND/OR HING CEILING, RELOCATE SUCH WIRING TO MAINTAIN THE CIRCUIT CONTINUITY.
- WHERE EXISTING WIRING AND CIRCUITRY TO REMAIN IS LEFT COVERED UP FROM FLOOR BY THE DEMOLITION AND REMOVAL OF PARTITIONS, RELOCATE SUCH WIRING AS REQUIRED TO MAINTAIN CIRCUIT CONTINUITY AND GET BACK COUPLER BELOW TOP OF FINISHED SLAB TO PERMIT FASINGING.
- WHERE EXISTING CIRCUITRY IS BEING UTILIZED FOR CONNECTION OF NEW LOADS OR BEING RETAINED FOR EXISTING LOADS AND SUCH CIRCUITRY IS NOT EXACTLY AS INDICATED ON PLANS, MAKE SUCH MODIFICATIONS AS MAY BE REQUIRED TO WIRING TO ACCOMPLISH THE DESIGN INTENT.
- WHERE EXISTING LIGHTING EQUIPMENT, WIRING, ETC. IS INDICATED AS REMAINING AND SUCH ITEMS INTERFERE WITH THE INSTALLATION OR THE DEMOLITION WORK OF OTHER TRADES, DISCONNECT, REMOVE, AND RELOCATE TO AVOID CONFLICTS. REINSTALL AND RECONNECT SUCH ITEMS AS REQUIRED.
- WHERE EXISTING FIXTURES ARE BEING REMOVED AND SUCH REMOVAL DISTURBS THE CIRCUITRY TO FIXTURES WHICH ARE TO REMAIN, PROVIDE ALL NECESSARY MODIFICATIONS AND ADDITIONS TO WIRING AS REQUIRED TO RETAIN SERVICE AND SWITCH CONTROL FOR REMAINING FIXTURES.
- WIRING INDICATED FOR BRANCH CIRCUITS ARE FOR GROUPING ONLY. ALL PANELBOARD DIRECTORIES ARE TO BE UPDATED FOR FUTURE REFERENCE.
- CONTRACTOR SHALL COORDINATE ALL DATA LOCATIONS, DEVICES, WIRING, EQUIPMENT, ETC. WITH COLLEGE PRIOR TO INSTALLATION FOR CONNECTION TO CAMPS SYSTEM.

KEY NOTES:

- EXISTING HOT WATER HEATER DISCONNECT SWITCHBREAKER TO REMAIN. CONTRACTOR TO DISCONNECT EXISTING WATER HEATER TO ALLOW FOR REPLACEMENT AND RE-CONNECT UPON INSTALLATION.
- EXISTING HVAC UNIT DISCONNECT SWITCHBREAKER TO REMAIN. CONTRACTOR TO RE-WIRE FROM PANELBOARD TO DISCONNECT SWITCHBREAKER.
- CONTRACTOR TO REFER TO ELECTRIC SERVICE UPGRADE DRAWINGS FOR WORK IN THIS AREA. CONSTRUCTION DOCUMENTS FOR THIS WORK FILED UNDER SEPARATE DCA PERMIT.

Revisions		
Date	Issue	Description
06-03-15	1	ISSUED FOR CONSTRUCTION

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA

955 Lincoln Ave. 2301 Dupont Drive-Suite 150
Glen Rock, New Jersey Irvine, California
07452 92512
t: 201.857.3998 t: 714.424.0001
f: 201.857.3994 f: 714.424.0004
www.linwoodengineering.com

Michael T. Davina, P.E. Robert J. Hatch, P.E.

NJ #48654 CT #0025779	AR #13868 CA #E16118 CT #13318 FL #69560 MA #48516 NJ #30419 NV #0199375 NY #56608 PA #036014-E
--------------------------	---

Project

INTERIOR RENOVATIONS
AT THE
BUTTERNUT - M RESIDENCE

RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client

RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

SNS Architects & Engineers, PC

1 PARAGON DRIVE . MONTVALE . NEW JERSEY . 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA	○
John M. Lignos, AIA	○
Lorin J. Sonenshine, AIA	○
Steven Napolitano, PE	○

Cert./Lic. No.	
Date	04-23-15
Drawn By	KER/Cadd
Dwg. Title	THIRD FLOOR POWER PLAN

Work Order No. Dwg. No.

4698M E301