


**SECOND FLOOR POWER PLAN**  
SCALE: 1/4"=1'-0"



**FIRST FLOOR POWER PLAN**  
SCALE: 1/4"=1'-0"

**POWER PLAN NOTES:**

- WHERE EXISTING WIRING AND CIRCUITRY WHICH IS TO REMAIN IS LEFT EXPOSED BY DEMOLITION AND REMOVAL OF PARTITION AND/OR HANG CEILING REMOVE SUCH WIRING TO MAINTAIN THE CIRCUIT CONTINUITY.
- WHERE EXISTING WIRING AND CIRCUITRY TO REMAIN IS LEFT STRIPPED UP FROM FLOOR BY THE DEMOLITION AND REMOVAL OF PARTITIONS REMOVE SUCH WIRING AS REQUIRED TO MAINTAIN CIRCUIT CONTINUITY AND GET BACK CONDUIT BELOW TOP OF FINISHED SLAB TO PERMIT PATCHING.
- WHERE EXISTING CIRCUITRY IS BEING UTILIZED FOR CONNECTION OF NEW LOAD OR BEING RETAINED FOR EXISTING LOADS AND SUCH CIRCUITRY IS NOT EXPLICITLY AS INDICATED ON PLANS, MAKE SUCH INDICATIONS AS MAY BE REQUIRED TO ACCOMPLISH THE DESIGN INTENT.
- WHERE EXISTING LIGHTING EQUIPMENT, WIRING, ETC. IS INDICATED AS REMAINING AND SUCH ITEMS INTERFERE WITH THE INSTALLATION OF THE DEMOLITION WORK OF OTHER TRADES, DISCONNECT, REMOVE, AND RELOCATE TO AVOID CONFLICTS. REINSTALL AND RECONNECT SUCH ITEMS AS REQUIRED.
- WHERE EXISTING FIXTURES ARE BEING REMOVED AND SUCH REMOVAL DECREASES THE CIRCUITRY TO FIXTURES WHICH ARE TO REMAIN, PROVIDE ALL NECESSARY MODIFICATIONS AND ADDITIONS TO WIRING AS REQUIRED TO RETAIN SERVICE AND SWITCH CONTROL FOR REMAINING FIXTURES. NUMBERS INDICATED FOR BRANCH CIRCUITS ARE FOR GROUPING ONLY.
- ALL PANELBOARDS DIRECTORIES ARE TO BE UPDATED FOR FUTURE REFERENCE.
- CONTRACTOR SHALL COORDINATE ALL DATA LOCATIONS, DEVICES, WIRING, EQUIPMENT, ETC. WITH COLLEGE PRIOR TO INSTALLATION FOR CONNECTION TO CAMPUS SYSTEM.


**KEY NOTES:**

- EXISTING HOT WATER HEATER DISCONNECT SWITCHBREAKER TO REMAIN. CONTRACTOR TO DISCONNECT EXISTING WATER HEATER TO ALLOW FOR REPLACEMENT AND RE-CONNECT UPON INSTALLATION.
- EXISTING HVAC UNIT DISCONNECT SWITCHBREAKER TO REMAIN. CONTRACTOR TO RE-WIRE FROM PANELBOARD TO DISCONNECT SWITCHBREAKER.
- CONTRACTOR TO REFER TO ELECTRIC SERVICE UPGRADE DRAWINGS FOR WORK IN THIS AREA. CONSTRUCTION DOCUMENTS FOR THIS WORK FILED UNDER SEPARATE DCA PERMIT.

**Revisions**

Date	Issue	Description
06-03-15	1	ISSUED FOR CONSTRUCTION
11-16-15	2	REVISED PER NJDOA ELECTRONIC STAMP

**Key Plan**



**Consultants**

**LINWOOD ENGINEERING ASSOCIATES, P.A.**

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

**LEA** 955 Lincoln Ave. 2001 Dupont Drive-Suite 150  
Glen Rock, New Jersey Irvine, California  
07452 92512  
t: 201.857.3998 f: 714.424.0001  
t: 201.857.3994 f: 714.424.0004  
www.linwoodengineering.com

**Project**

INTERIOR RENOVATIONS  
AT THE  
**BUTTERNUT - M RESIDENCE**  
**RAMAPO COLLEGE**  
OF NEW JERSEY  
505 Ramapo Valley Road  
Mahwah, New Jersey 07430-1680

**Client**

**RAMAPO COLLEGE**  
OF NEW JERSEY  
505 Ramapo Valley Road  
Mahwah, New Jersey 07430-1680

**SNS** Architects & Engineers, PC  
1 PARAGON DRIVE, MONTVALE, NEW JERSEY 07645  
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA  
John M. Lignos, AIA  
Lorin J. Sonenshine, AIA  
Steven Napolitano, PE

**Michael T. Davina, P.E.**  
NJ #48654  
CT #0025779  
**Robert J. Hatch, P.E.**  
AR #13868  
CA #E16118  
CT #15318  
FL #69560  
MA #48516  
NJ #55419  
NY #019975  
PA #036014-E

Cert./Lic. No.  
Date 04-23-15 Scale AS NOTED  
Drawn By KEB/CAD Checked By MD  
Dwg. Title  
**FIRST & SECOND FLOOR POWER PLANS**  
Work Order No. Dwg. No.

**4698M E300**