

THIRD FLOOR LIGHTING PLAN
SCALE: 1/4"=1'-0"


LIGHTING NOTES:

- WHERE EXISTING WIRING AND CIRCUITRY WHICH IS TO REMAIN IS LEFT EXPOSED BY DEMOLITION AND REMOVAL OF PARTITION AND/OR HINGE CEILING, RELOCATE SUCH WIRING TO MAINTAIN THE CIRCUIT CONTINUITY.
- WHERE EXISTING WIRING AND CIRCUITRY TO REMAIN IS LEFT SUBMERGED UP FRONT FLOOR BY THE DEMOLITION AND REMOVAL OF PARTITIONS, RELOCATE SUCH WIRING AS REQUIRED TO MAINTAIN CIRCUIT CONTINUITY AND GET BACK CONDUIT BELOW TOP OF FINISHED SLAB TO PERMIT PATINGING.
- WHERE EXISTING CIRCUITRY IS BEING UTILIZED FOR CONNECTION OF NEW LOADS OR BEING REWIRED FOR EXISTING LOADS AND SUCH CIRCUITRY IS NOT EXACTLY AS INDICATED ON PLANS, MAKE SUCH MODIFICATIONS AS MAY BE REQUIRED TO WIRING TO ACCOMPLISH THE DESIGN INTENT.
- WHERE EXISTING LIGHTING EQUIPMENT, WIRING, ETC., IS INDICATED AS REMAINING AND SUCH ITEMS INTERFERE WITH THE INSTALLATION OR THE DEMOLITION WORK OF OTHER TRADES, DISCONNECT, REMOVE, AND RELOCATE TO AVOID CONFLICTS. REINSTALL AND RECONNECT SUCH ITEMS AS REQUIRED.
- WHERE EXISTING FIXTURES ARE BEING REMOVED AND SUCH REMOVAL DISTURBS THE CIRCUITRY TO FIXTURES WHICH ARE TO REMAIN, PROVIDE ALL NECESSARY MODIFICATIONS AND ADDITIONS TO WIRING AS REQUIRED TO RETAIN SERVICE AND SWITCH CONTROL FOR REMAINING FIXTURES.
- NUMBERS INDICATED FOR BRANCH CIRCUITS ARE FOR GROUPING ONLY.
- ALL PANELBOARD DIRECTORIES ARE TO BE UPDATED FOR FUTURE REFERENCE.

Revisions

| Date | Issue | Description |
|----------|-------|------------------------------------|
| 06-03-15 | 1 | ISSUED FOR CONSTRUCTION |
| 11-16-15 | 2 | REVISED PER NUDCO ELECTRONIC STAMP |

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA

955 Lincoln Ave.
Glen Rock, New Jersey 07452
t: 201.857.3998
f: 201.857.3984

2301 Dupont Drive-Suite 150
Irvine, California 92612
t: 714.424.0001
f: 714.424.0004
www.linwoodengineering.com

Project

INTERIOR RENOVATIONS
AT THE
BUTTERNUT - M RESIDENCE



RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client



RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680


SNS

Architects & Engineers, PC

1 PARAGON DRIVE . MONTVALE . NEW JERSEY . 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA
John M. Lignos, AIA
Lorin J. Sonenshine, AIA
Steven Napolitano, PE

☐
☐
☐
☐



Cert./Lic. No.
Date 04-23-15
Drawn By KEB/Cadd
Dwg. Title
THIRD FLOOR LIGHTING PLAN

Scale
AS NOTED

Checked By
ND

Work Order No.
4698M

Dwg. No.
E201

Michael T. Davina, P.E.
NJ #48654
CT #0025779

Robert J. Hatch, P.E.
AR #13868
CA #E16118
CT #15318
FL #69560
MA #48516
NJ #35419
NV #019975
NY #56608
PA #036014-E