

KEY NOTES:


- EXISTING PACKAGED VERTICAL A/C UNIT.
- NEW EXHAUST FAN MANUFACTURED BY BROWAN MODEL "6"1" TO CONNECT TO EXISTING DUCT RISER WITH 4" DUCT. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
- SEAL ALL JOINTS IN EXISTING TOILET AND KITCHEN EXHAUST DUCT RISER WITH NEW MASTIC.
- NEW 10"X16"1/4" DUCT TRANSITION TO 6"X TO RUN IN CEILING TO CONNECT TO EXISTING EXHAUST DUCT RISER. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
- NEW SUPPLY GRILLE MANUFACTURED BY TITUS MODEL "3006L" OR APPROVED EQUAL. NEW GRILLE NECK AND FRAME SIZE TO MATCH EXISTING.
- RE-INSTALL EXISTING THERMOSTAT/TEMPERATURE SENSOR. REPLACE AS REQUIRED IF DAMAGED DURING CONSTRUCTION (TYP)
- EXISTING SUPPLY GRILLE TO REMAIN.

THIRD FLOOR HVAC PLAN
SCALE: 1/4"=1'-0"

Revisions

Date	Issue	Description
06-03-15	1	ISSUED FOR CONSTRUCTION

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA 955 Lincoln Ave. 2301 Dupont Drive-Suite 150
Glen Rock, New Jersey Irvine, California
07452 92612
t: 201.857.3998 t: 714.424.0001
f: 201.857.3994 f: 714.424.0004
www.linwoodengineering.com

Michael T. Davina, P.E. **Robert J. Hatch, P.E.**

NJ #48654 AR #13868
CT #0025779 CA #E16118
CT #13318 CT #13318
FL #69560 FL #69560
MA #48516 MA #48516
NJ #30419 NJ #30419
NV #0199375 NV #0199375
NY #56608 NY #56608
PA #036014-E

Project

INTERIOR RENOVATIONS
AT THE
BUTTERNUT - M RESIDENCE
RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client

RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

SNS Architects & Engineers, PC
1 PARAGON DRIVE . MONTVALE . NEW JERSEY . 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA
John M. Lignos, AIA
Lorin J. Sonenshine, AIA
Steven Napolitano, PE

Cert./Lic. No.
Date 04-23-15 Scale AS NOTED
Drawn By PSCadd Checked By MD
Dwg. Title
THIRD FLOOR HVAC PLAN

Work Order No. Dwg. No.

4698M M201