

KEY NOTES:


1. EXISTING PACKAGED VERTICAL A/C UNIT TO REMAIN.
2. REMOVE EXISTING TOILET EXHAUST FAN AND FLEXIBLE DUCT.
3. EXISTING 4" TOILET EXHAUST DUCT RISER TO REMAIN. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
4. REMOVE EXISTING HOOD EXHAUST DUCT.
5. EXISTING 6" HOOD EXHAUST DUCT RISER TO REMAIN. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
6. REMOVE EXISTING SUPPLY GRILLES.
7. REMOVE EXISTING THERMOSTAT/TEMPERATURE SENSOR AND TEMPORARILY SUPPORT DURING DEMOLITION.
8. EXISTING SUPPLY GRILLE TO REMAIN.

THIRD FLOOR HVAC DEMOLITION PLAN
SCALE: 1/4"=1'-0"

Revisions

Date	Issue	Description
06-03-15	1	ISSUED FOR CONSTRUCTION
11-16-15	2	REVISED PER NUDCA ELECTRONIC STAMP

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA

955 Lincoln Ave.
Glen Rock, New Jersey 07452
t: 201.857.3998
f: 201.857.3984

2301 Dupont Drive-Suite 150
Irvine, California 92612
t: 714.424.0001
f: 714.424.0004
www.linwoodengineering.com

Project

INTERIOR RENOVATIONS
AT THE
BUTTERNUT - M RESIDENCE



RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client



RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

SNS

Architects & Engineers, PC

1 PARAGON DRIVE . MONTVALE . NEW JERSEY . 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA
John M. Lignos, AIA
Lorin J. Sonenshine, AIA
Steven Napolitano, PE

☐
☐
☐
☐

Cert./Lic. No.
Date
Drawn By
Dwg. Title

04-23-15
PVCadd
THIRD FLOOR HVAC DEMOLITION PLAN

A5 NOTED
MD

Work Order No.
4698M

Dwg. No.
M101

Michael T. Davina, P.E.
NJ #48654
CT #0025779

Robert J. Hatch, P.E.
AR #13868
CA #E16118
CT #15318
FL #69560
MA #48516
NJ #35419
NY #019975
PA #036014-E