


KEY NOTES:

- EXISTING PACKAGED VERTICAL A/C UNIT TO REMAIN.
- REMOVE EXISTING TOILET EXHAUST FAN AND FLEXIBLE DUCT.
- EXISTING 4" TOILET EXHAUST DUCT RISER TO REMAIN. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
- REMOVE EXISTING HOOD EXHAUST DUCT.
- EXISTING 6" HOOD EXHAUST DUCT RISER TO REMAIN. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
- REMOVE EXISTING SUPPLY GRILLES.
- REMOVE EXISTING THERMOSTAT/TEMPERATURE SENSOR AND TEMPORARILY SUPPORT DURING DEMOLITION.
- EXISTING SUPPLY GRILLE TO REMAIN.

Revisions

Date	Issue	Description
06-03-15	1	ISSUED FOR CONSTRUCTION
11-16-15	2	REVISED PER NJDOCA ELECTRONIC STAMP

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA 955 Lincoln Ave. 2301 Dupont Drive-Suite 150
Glen Rock, New Jersey Irvine, California
07452 92512
t: 201.857.3998 f: 714.424.0001
r: 201.857.3994 f: 714.424.0004
www.linwoodengineering.com

Project

INTERIOR RENOVATIONS
AT THE
TAMARACK - N RESIDENCE


RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client

RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

SNS Architects & Engineers, PC
1 PARAGON DRIVE . MONTVALE . NEW JERSEY . 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA
John M. Lignos, AIA
Lorin J. Sonenshine, AIA
Steven Napolitano, PE



Cert./Lic. No.
Date 04-10-15 Scale AS NOTED
Drawn By MD Checked By 96
Dwg. Title
THIRD FLOOR HVAC DEMOLITION PLAN

Work Order No. 4698N Dwg. No. M102

Michael T. Davina, P.E.
NJ #48654
CT #0025779

Robert J. Hatch, P.E.
AR #13868
CA #E16118
CT #15318
FL #69560
MA #48516
NJ #35419
NV #019975
NY #56608
PA #036014-E

MATCH
LINE

THIRD FLOOR HVAC DEMOLITION PLAN
SCALE: 1/4"=1'-0"