

| SYMBOL | DEVICE | MANUFACTURER | MODEL NO. |
|-------------------------------------------------------------------------------------|---------------------------------------------------------------|-------------------------------|------------|
|  | FIRE ALARM CONTROL PANEL | NOTIFIER | NFS-320 |
|  | GATEWAY | NOTIFIER | NN-GW-EM-3 |
|  | DIGITAL COMMUNICATOR | NOTIFIER | 4II-UD |
|  | MANUAL PULL STATION | NOTIFIER | NBS-DLX |
|  | ADDRESSABLE, PHOTOELECTRIC SMOKE DETECTOR | NOTIFIER | FSP-851 |
|  | ADDRESSABLE, PHOTOELECTRIC SMOKE DETECTOR WITH SOUNDER BASE | NOTIFIER | FSP-851 |
|  | ADDRESSABLE, RATE OF RISE, HEAT DETECTOR | NOTIFIER | FSP-858R |
|  | ADDRESSABLE, HIGH TEMP. RATE OF RISE, HEAT DETECTOR | NOTIFIER | FSP-859H |
|  | ADDRESSABLE, COMBINATION FIRE/CARBON MONOXIDE DETECTOR | NOTIFIER | FCO-851 |
|  | COMBINATION, ADJUSTABLE CANDELA STROBE LIGHT | SYSTEM SENSOR | SR |
|  | ADJUSTABLE, ADJUSTABLE CANDELA, HORN AND STROBE | SYSTEM SENSOR | P2R |
|  | COMBINATION, ADJUSTABLE CANDELA, HORN AND STROBE WEATHERPROOF | SYSTEM SENSOR | P2RKC |
|  | ADDRESSABLE MONITOR MODULE | NOTIFIER | PM4-I |
|  | LOW TEMPERATURE SWITCH | POTTER | RTS-O |
|  | TAMPER SWITCH | BY FIRE PROTECTION CONTRACTOR | |
|  | FLOW SWITCH | BY FIRE PROTECTION CONTRACTOR | |
|  | PRESSURE SWITCH | BY FIRE PROTECTION CONTRACTOR | |
|  | POST INDICATOR VALVE | EXISTING | |

4698N E403

| | | | | | | |
|----------------------------------------|------------------------------|---|---|---|---|---|
| SYSTEM CONDITION | AREA SMOKE DETECTOR | X | X | X | X | |
| | BEDROOM SMOKE DETECTOR | X | X | X | X | |
| | MANUAL PULL STATION | X | X | X | X | |
| | HEAT DETECTOR | X | X | X | X | |
| | COMBINATION FIRE/CO DETECTOR | X | X | X | X | |
| | WATERFLOW SWITCH | X | X | X | X | |
| | PRESSURE SWITCH | X | X | X | X | |
| | LOW TEMPERATURE SWITCH | | | | | X |
| | TAMPER SWITCH | | | | | X |
| | POST INDICATOR VALVE TAMPER | X | X | X | X | |
| FIELD WIRING OR SYSTEM COMPONENT FAULT | | | | | X | |
| LOSS OF PRIMARY AC POWER | X | X | X | X | | |

FIRE ALARM SYSTEM FUNCTION MATRIX

Robert J. Hatch, P.E.
AR #13868
CA #E16118
CT #13318
FL #69560
MA #48516
NJ #30419
NV #019975
NY #56608
PA #036014-E

AR #13868
CA #E16118
CT #13318
FL #69560
MA #48516
NJ #30419
NV #019975
NY #56608
PA #036014-E