


- KEY NOTES:**
- EXISTING PACKAGED VERTICAL A/C UNIT TO REMAIN.
 - REMOVE EXISTING TOILET EXHAUST FAN AND FLEXIBLE DUCT.
 - EXISTING 4" P TOILET EXHAUST DUCT RISER TO REMAIN. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
 - REMOVE EXISTING HOOD EXHAUST DUCT.
 - EXISTING 8" P HOOD EXHAUST DUCT RISER TO REMAIN. VERIFY EXISTING LOCATION OF DUCT RISER IN FIELD.
 - REMOVE EXISTING SUPPLY GRILLES.
 - REMOVE EXISTING THERMOSTAT/TEMPERATURE SENSOR AND TEMPORARILY SUPPORT DURING DEMOLITION.
 - EXISTING SUPPLY GRILLE TO REMAIN.




SECOND FLOOR HVAC DEMOLITION PLAN
SCALE: 1/4"=1'-0"

Revisions

Date	Issue	Description
06-03-15	1	ISSUE FOR CONSTRUCTION

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA 955 Lincoln Ave. 2301 Dupont Drive-Suite 150
Glen Rock, New Jersey Irvine, California
07452 92512
t: 201.857.3998 t: 714.424.0001
f: 201.857.3994 f: 714.424.0004
www.linwoodengineering.com

Michael T. Davina, P.E. **Robert J. Hatch, P.E.**

NJ #48654 AR #13868
CT #0025779 CA #E16118
CT #13318 FL #69560
MA #48516
NJ #30419
NV #019975
NY #56608
PA #036014-E

Project

INTERIOR RENOVATIONS
AT THE
TAMARACK - N RESIDENCE



505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client



505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

SNS Architects & Engineers, PC
1 PARAGON DRIVE, MONTVALE, NEW JERSEY 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA
John M. Lignos, AIA
Lorin J. Sonenshine, AIA
Steven Napolitano, PE

Cert./Lic. No.
Date 04-10-15 Scale AS NOTED
Drawn By MD Checked By SE

Dwg. Title
SECOND FLOOR HVAC DEMOLITION PLAN

Work Order No. Dwg. No.

4698N M101