

MECHANICAL NOTES AND SPECIFICATIONS

- I. GENERAL
- A. CONTRACTOR SHALL PERFORM ALL WORK AS TO CONFORM TO LOCAL, STATE AND NATIONAL CODES AND THE REQUIREMENTS OF LOCAL AUTHORITIES HAVING JURISDICTION.
- B. CONTRACTOR TO EXAMINE THE SITE TO DETERMINE THE EXACT CONDITIONS EFFECTING THE MECHANICAL WORK. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS NOTED ON THE PLANS.
- C. DRAWINGS INDICATE THE GENERAL SCHEME OF THE INSTALLATION AND ARE DIAGNRAMATIC IN SCOPE. THE ENGINEER RESERVES THE RIGHT TO CHANGE THE LOCATION OF DUCTWORK, PIPING, DEFIZERS, APPARATUS, ETC., TO A REASONABLE EXTENT AS THE BUILDING CONDITIONS MAY DICTATE PRIOR TO THEIR INSTALLATION WITHOUT EXTRA COST TO THE OWNER. THE EXACT LOCATION AND ARRANGEMENT OF ALL EQUIPMENT AND PARTS SHALL BE DETERMINED AS THE WORK PROGRESSES.
- D. DETAILS OF CONSTRUCTION AND OF WORKMANSHIP WHERE NOT SPECIFICALLY DESCRIBED HEREIN OR INDICATED ON THE DRAWINGS SHALL BE SUBJECT TO THE ENGINEER'S APPROVAL. IT IS THE INTENT OF THESE SPECIFICATIONS TO PROVIDE COMPLETE SYSTEMS CONSTRUCTED WITH NEW AND FIRST QUALITY MATERIALS AND EQUIPMENT, LEFT IN GOOD WORKING ORDER, READY FOR OPERATION.
- E. SCRAP, DEBRIS AND ABANDONED HVAC EQUIPMENT, DUCTWORK, SUPPORTS, CONTROLS AND ACCESSORIES SHALL, EXCEPT AS OTHERWISE SPECIFIED, BE REMOVED FROM THE SITE AND DISPOSED OF BY THIS CONTRACTOR.
- F. THE CONTRACTOR SHALL BE RESPONSIBLE FOR START-UP OF ALL SYSTEMS.
- G. ALL WORK SHALL BE DONE WITH A MINIMUM OF DUST AND DIRT. PROVIDE SUFFICIENT FIREPROOF TARPALLING AND COVER ALL EQUIPMENT IN WORK AREA WITH SALES DURING WORK OPERATIONS.
- H. CONTRACTOR SHALL FURNISH SHOP DRAWINGS AND EQUIPMENT CUTS TO THE ARCHITECT FOR APPROVAL (MINIMUM (5) COPIES). THE ENGINEER'S APPROVAL SHALL NOT RELIEVE THE CONTRACTOR FROM HIS OBLIGATION TO COMPLY WITH THE INFORMATION CONTAINED IN THE CONTRACT DOCUMENTS.
- I. CONTRACTOR SHALL COORDINATE CONNECTIONS TO STREET WITH LOCAL UTILITY COMPANIES.
- J. CONTRACTOR SHALL FILE, SECURE AND PAY FOR ANY NECESSARY APPROVALS, PERMITS AND INSPECTIONS.
- K. ALL WORK SHALL BE IN STRICT CONFORMANCE WITH THE STATE OF NEW JERSEY UNIFORM CONSTRUCTION CODE, THE STATE OF NEW JERSEY INFROM FIRE CODE (NJAC 9-10), THE STATE OF NEW JERSEY FIRE PREVENTION CODE, THE INTERNATIONAL BUILDING CODE, THE INTERNATIONAL MECHANICAL CODE AND THE ASHRAE 90I-2007, ENERGY CONSERVATION CODE.
- L. PRIOR TO TESTING, CONTRACTOR SHALL MAKE ALL SYSTEM ADJUSTMENTS REQUIRED FOR PROPER OPERATION. ADJUSTMENTS SHALL INCLUDE AIR BALANCING, HYDRONIC BALANCING, ETC.
- M. ALL SYSTEMS SHALL BE TESTED IN ACCORDANCE WITH THE INTERNATIONAL MECHANICAL CODE AND THE STATE OF NEW JERSEY FIRE PREVENTION CODE. CONTRACTOR TO COORDINATE TESTS WITH LOCAL OFFICIALS.
- N. CONTRACTOR SHALL BE RESPONSIBLE FOR DISCONNECTING ALL FACILITIES IN AREAS INDICATED FOR DEMOLITION ON THE ARCHITECTURAL DRAWINGS.
- O. WHERE DEMOLITION OF EXISTING SERVICES RESULTS IN THE INTERRUPTION OF DUCTWORK, MECHANICAL PIPING, ETC., SERVING AREAS WHICH TO REMAIN, INSTALL BYPASS CONNECTIONS AS REQUIRED TO RESTORE REMAINING SERVICES TO OPERATION. SIZING, MATERIAL, JOINTINGS AND INSULATION OF BYPASS CONNECTIONS SHALL MATCH EXISTING INSTALLATION.
- P. ALL WORK SHALL BE GUARANTEED TO BE FREE FROM DEFECT FOR ONE YEAR AFTER ACCEPTANCE OF WORK.
- Q. THE CONTRACTOR'S PROPOSAL AND BASE BID MUST COVER ALL ITEMS IN THE PLANS AND SPECIFICATIONS/NOTES EXACTLY AS DRAWN, NOTED, SCHEDULED, DETAILED AND SPECIFIED. TO RECEIVE CONSIDERATION FOR A SUBSTITUTION OF MATERIALS AND/OR EQUIPMENT, THE CONTRACTOR MUST INCLUDE THE FOLLOWING INFORMATION WITH HIS BASE BID:
- DOCUMENTATION OF EQUALITY, A SIDE-BY-SIDE COMPARISON, OF PERFORMANCE AND CONSTRUCTION MATERIALS, BETWEEN THE SPECIFIED ITEM AND THE PROPOSED SUBSTITUTION.
 - THE DOLLAR VALUE FOR CREDIT, ASSOCIATED WITH THE SUBSTITUTED ITEM(S), SHALL BE ITEMIZED IN THE BASE BID.
- R. IN ACCORDANCE WITH IMC 2004, SECTION 602.1, THE FOLLOWING REQUIREMENTS SHALL APPLY TO ALL WORKING LOCATED IN A PLENUM CEILING:
- a. MUST BE LOW VOLTAGE OR POWER LIMITED.
 - b. FLAME SPREAD NOT GREATER THAN FIVE FEET.
 - c. WIRE SHALL BEAR THE LABEL OF AN APPROVED AGENCY AND BE MARKED IN ACCORDANCE WITH NFPA 70.
 - d. THERMAL AND ACOUSTICAL MATERIALS AND PIPE INSULATION MUST HAVE A FLAME SPREAD RATING OF 25 OR LESS AND A SMOKE DEVELOPED RATING RATING OF 50 OR LESS WHEN TESTED IN ACCORDANCE WITH ASTM E84.
2. SCOPE OF WORK
- A. THE WORK SHALL INCLUDE BUT NOT BE LIMITED TO THE FOLLOWING:
- B. FURNISH AND INSTALL ALL NEW EXHAUST AIR DUCTWORK.
- C. FURNISH AND INSTALL INSULATION FOR ALL SUPPLY & RETURN AIR DUCTWORK.
- D. FURNISH AND INSTALL ALL FAN COIL UNITS AS SHOWN ON DRAWINGS AND SPECIFIED IN SCHEDULES.
- E. FURNISH AND INSTALL ALL CEILING MOUNTED CABINET EXHAUST FANS AS SHOWN ON DRAWINGS AND SPECIFIED IN SCHEDULES.
- F. FURNISH AND INSTALL ALL HANGERS AND SUPPORTS.
- G. FURNISH AND INSTALL ALL HOT/CHILLED WATER PIPES FOR FAN COIL UNITS AS REQUIRED.
- H. SHOP DRAWINGS.
- I. ENGAGE THE SERVICES OF AN APPROVED INDEPENDENT AIR BALANCING COMPANY TO BALANCE THE SYSTEMS, AND ISSUE AN AIR BALANCING REPORT. THE INDEPENDENT AIR BALANCING COMPANY SHALL BE SUBJECT TO THE ENGINEER'S APPROVAL. IF NECESSARY, PROVIDE MANUAL VOLUME DAMPERS AT BRANCH DUCTWORK TO ASSURE PROPER AIR BALANCE.
- J. ALTERATIONS, REMOVALS, AND DISPOSAL.
- K. CUTTING AND ROUGH PATCHING.
- L. OBTAINING AND PAYING FOR ALL NECESSARY PERMITS, INSPECTIONS AND CERTIFICATES REQUIRED IN CONNECTION WITH THIS WORK. AIR DUCTWORK.
- M. REMOVE ALL WORK INDICATED ON THE DRAWINGS.
- N. REMOVE ALL EXISTING HVAC EQUIPMENT AS SHOWN ON PLANS.
- O. FURNISH AND INSTALL INSULATION FOR ALL HOT/CHILLED WATER PIPING.
- P. GUARANTEE ALL WORK FOR A PERIOD OF ONE YEAR FROM THE FINAL DATE OF ACCEPTANCE.

3. WORK NOT INCLUDED
- A. THE FOLLOWING ITEMS OF WORK SHALL BE PROVIDED UNDER OTHER CONTRACTS:
- A. FINISHED PATCHING AND PAINTING.
4. NOISE CONTROL
- A. ALL INSTALLATION SHALL BE IN A MANNER THAT THE NOISE CRITERIA LEVEL IN THE SPACE SHALL NOT EXCEED NC-35. NOISE LEVELS ABOVE THIS LIMIT WILL NOT BE ACCEPTABLE AND SHOULD BE CORRECTED BY THIS CONTRACTOR AT NO EXPENSE TO THE OWNER.
- B. ALL SUPPLY AND RETURN DUCTWORK SHALL BE PROVIDED WITH 1" INTERNAL ACOUSTIC LINING AT LEAST 20" FROM EACH AIR HANDLING UNIT. ALL DUCTWORK DIMENSIONS NOTED ON THE PLANS ARE CLEAR INSIDE DIMENSIONS.
5. VIBRATION CONTROL
- A. ALL INSTALLATIONS SHALL BE IN SUCH A MANNER THAT VIBRATION FROM ROTATING EQUIPMENT IS ISOLATED FROM DUCTWORK, PIPING AND THE BUILDING STRUCTURE.
- B. FLEXIBLE CONNECTIONS SHALL BE PROVIDED AT ALL LOCATIONS WHERE RIGID DUCTWORK CONNECTS TO FANS, AIR HANDLERS, OR OTHER EQUIPMENT CAPABLE OF PRODUCING OBJECTIONABLE VIBRATION. FLEXIBLE CONNECTIONS SHALL BE 30 OZ. NEOPRENE COATED FABRIC SECURED WITH HEAVY DUTY BANDS OR CRIMPS.
- C. FLEXIBLE CONNECTIONS SHALL BE PROVIDED AT ALL LOCATIONS WHERE PIPING CONNECTS TO PUMPS OR OTHER EQUIPMENT CAPABLE OF PRODUCING OBJECTIONABLE VIBRATION.
- D. ALL EQUIPMENT SUPPORTED FROM THE BUILDING STRUCTURE SHALL BE PROVIDED WITH SPRING-TYPE VIBRATION ISOLATORS.
6. SHEET METAL DUCTWORK
- A. ALL RECTANGULAR DUCTWORK, UNLESS OTHERWISE NOTED, SHALL BE BUILT FROM GALVANIZED SHEET STEEL AND THOROUGHLY BRACED & STIFFENED. ALL DUCTWORK DIMENSIONS NOTED ON THE PLANS ARE CLEAR INSIDE DIMENSIONS.
- B. FABRICATION OF SHEET METAL DUCTS SHALL BE IN ACCORDANCE WITH RECOMMENDATIONS OF ASHRAE, LATEST EDITION, OR AS PER SHACMA DUCT CONSTRUCTION MANUALS. ALL BRANCH DUCTWORK, AND TAKE-OFFS SHALL BE PROVIDED WITH VOLUME DAMPERS.
- C. CONTRACTOR SHALL SEAL ALL DUCTWORK JOINTS WITH 3M EG-800 OR APPROVED EQUAL.
- D. UNLESS OTHERWISE NOTED, ALL DUCTWORK SHALL BE CONCEALED WITHIN CEILING, WALLS, FLOORS AND SHAFTS.
- E. ALL DUCTWORK GAUGES AND INSTALLATION SHALL CONFORM TO THE LATEST EDITION OF SHACMA STANDARDS.
- F. CHANGES IN SHAPE AND DIMENSION SHALL CONFORM TO THE FOLLOWING, EXCEPT WHERE OTHERWISE NOTED FOR INCREASES IN CROSS-SECTIONAL AREA, THE SHAPE OF THE TRANSFORMATION SHALL NOT EXCEED 1" IN 1' SPACE. CONDITIONS PERMITTING, EXCEPT WHERE OTHERWISE NOTED, FOR REDUCTIONS IN AREA, THE SLOPE SHALL NOT BE LESS THAN 1" IN 1'. SPACE CONDITIONS PERMITTING.

LOW PRESSURE, RECTANGULAR/ROUND DUCTWORK STANDARDS				
DIMENSION OF LONGEST SIDE OF DUCT (INCHES)	MINIMUM GAUGE OF SHEET METAL FOR ALL FOUR SIDES OF DUCT	TRANSVERSE REINFORCING AT AND BETWEEN DUCT JOINTS		
		STEEL (GAUGE)	ALUMINUM THICKNESS (INCHES)	
UP THRU 12	26	0.020	1" POCKET LOCK 24 GAUGE, STANDING SEAM JOINT 24 GAUGE, 1" STANDING S LIP 24 GAUGE, JOINT MAX. ON 8 FT. CENTERS.	

- H. FLAT AREAS OF DUCT OVER 16 IN. WIDE SHALL BE STIFFENED BY CROSS BREAKING OF BEADING.
- I. ALL JOINTS SHALL HAVE CORNER CLOSURES.
- J. PROVIDE 3M CO-5 GASKET EG-1202 GASKET AT FLANGED JOINTS AND ALL SLIP JOINTS SHALL BE SEALED WITH 3M CO-5 EG-800. JOINTS SHALL BE MAXIMUM ON 8 FEET CENTERS.
- K. THIS CONTRACTOR MAY ELECT THE OPTION OF USING STANDARD PREFABRICATED SPIRAL CONSTRUCTION CONDUIT AND PREFABRICATED FITTINGS AS MADE BY UNITED SPIRAL CO. OR APPROVED EQUAL. ALL JOINTS SHALL BE SEALED WITH 3M CO-5 EG-800.
- L. ALL JOINTS IN A DUCT SYSTEM MUST BE TIGHT IN ORDER TO ENSURE PROPER AIR DISTRIBUTION AND STRUCTURAL INTEGRITY. DUCT SUPPORT SHALL NOT EXCEED 10 FEET.
7. FLEXIBLE DUCTWORK
- A. FLEXIBLE DUCTWORK SHALL BE PERMITTED FOR USE BETWEEN BRANCH DUCTWORK AND CEILING DIFFUSERS IN LENGTHS NOT EXCEEDING 6'-0".
- B. LOW PRESSURE FLEXIBLE DUCTWORK SHALL BE A FACTORY ASSEMBLY OF LOW FRICTION POLYMER INNER LINER APPLIED OVER A MECHANICALLY INTERLOCKED, GALVANIZED STEEL HELIX. INSULATION SHALL BE FIBERGLASS WITH A THERMAL CONDUCTANCE OF NOT MORE THAN 0.23. THE OVERALL ASSEMBLY SHALL BE JACKETED WITH A POLYETHYLENE VAPOR BARRIER HAVING A PERMEANCE OF NOT GREATER THAN 0.1 WHEN TESTED IN ACCORDANCE WITH ASTM M96. PROCEDURE A, ASSEMBLY SHALL BE RATED FOR A MAXIMUM WORKING PRESSURE OF 4" H₂O. POSITIVE, 4" H₂O. NEGATIVE, 4.000 FPM MAXIMUM VELOCITY AND -20°F TO 250°F OPERATING TEMPERATURE. MINIMUM BURST PRESSURE SHALL BE NOT LESS THAN 250% OF RATED WORKING PRESSURE. DUCT SHALL BE LISTED AS CLASS 07 OR CLASS 1 FLEXIBLE AIR DUCT UNDER UL 181 AND SHALL BE SO IDENTIFIED.
- C. FLAME SPREAD RATING SHALL BE LESS THAN 25. UL SMOKE DEVELOPED RATING SHALL BE LESS THAN 50. LOW PRESSURE FLEXIBLE DUCT SHALL BE "TYPE 4-INSULATED" AS MANUFACTURED BY FLEXMASTER U.S.A., INC. OR ENGINEER APPROVED EQUAL.
- D. ALL FLEXIBLE DUCTWORK SHALL BE SECURED USING HEAVY DUTY, STAINLESS STEEL CLAMPS.

8. PIPING

- A. ALL PIPE SHALL BE NEW, FREE FROM SCALE OR RUST, OF THE MATERIAL AND HEIGHT SPECIFIED UNDER THE VARIOUS SERVICES. EACH LENGTH OF PIPE SHALL BE PROPERLY MARKED AT THE MILL FOR PROPER IDENTIFICATION WITH NAME OR SYMBOL OF MANUFACTURER.
- B. ALL FITTINGS USED AT EXPANSION LOOPS OR BENDS SHALL BE EXTRA HEAVY.
- C. ALL HOT/CHILLED WATER PIPING SHALL BE SCHEDULE 40 STEEL.
- D. PROVIDE NECESSARY STRUCTURAL, VEHICULAR, HANGERS AND SUPPORTS OF APPROVED DESIGN TO KEEP PIPING IN PROPER ALIGNMENT AND PREVENT TRANSMISSION OF INJURIOUS THRUSTS AND VIBRATIONS. IN ALL CASES WHERE HANGERS, BRACKETS, ETC., ARE SUPPORTED FROM METAL, DECKING AND/OR CONCRETE CONSTRUCTION, CARE SHALL BE TAKEN NOT TO WEAKEN DECKING AND/OR CONCRETE OR PENETRATE WATERPROOFING. ALL HANGERS AND SUPPORTS SHALL BE CAPABLE OF SLOREN ADJUSTMENT AFTER PIPING IS ERECTED. HANGERS SUPPORTING PIPING EXPANDING INTO LOOPS, BENDS AND OFFSETS SHALL BE SECURED TO THE BUILDING STRUCTURE IN SUCH A MANNER THAT HORIZONTAL ADJUSTMENT PERPENDICULAR TO THE RUN OF PIPING SUPPORTED MAY BE MADE TO ACCOMMODATE DISPLACEMENT DUE TO EXPANSION. ALL SUCH HANGERS SHALL BE FINALLY ADJUSTED, BOTH IN THE VERTICAL AND HORIZONTAL DIRECTION WHEN THE SUPPORTED PIPING IS HOT OR CHILLED, AS REQUIRED.
- E. ALL VERTICAL PIPING SHALL BE ANCHORED BY MEANS OF HEAVY STEEL CLAMPS SECURELY BOLTED OR WELDED TO THE PIPING AND WITH END EXTENSION BEARING ON THE BUILDING.
- F. ALL PIPING SHALL BE ERECTED SO AS TO ENSURE A PERFECT AND NOISELESS CIRCULATION THROUGHOUT THE SYSTEM.
- G. ALL VALVES AND SPECIALTIES SHALL BE SO PLACED AS TO PERMIT EASY OPERATION AND ACCESS.
- H. PROVIDE PROPER PROVISION FOR EXPANSION AND CONTRACTION IN ALL PORTIONS OF PIPEWORK, TO PREVENT UNDE STRAINS ON PIPING OR APPARATUS CONNECTED THEREWITH. PROVIDE DOUBLE SWINGS AT RISER TRANSFERS AND OTHER OFFSETS WHEREVER POSSIBLE TO TAKE UP EXPANSION, ARRANGE RISER BRANCHES TO TAKE UP MOTION OF RISER.
- I. THE ENDS OF ALL PIPE AND NIPPLES SHALL BE THOROUGHLY SEALED TO THE FULL INSIDE DIAMETER OF THE PIPE AND ALL BIRRS FORMED IN THE CUTTINGS OF THE PIPES SHALL BE REMOVED.
- J. PIPING SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITION OF THE ASME CODE FOR PRESSURE PIPING.
- K. PIPING AT ALL EQUIPMENT AND CONTROL VALVES SHALL BE SUPPORTED TO PREVENT STRAINS OR DISTORTIONS IN THE CONNECTED EQUIPMENT AND CONTROL VALVES. PIPING SHALL BE SUPPORTED TO ALLOW FOR REMOVAL OF EQUIPMENT, VALVES AND ACCESSORIES WITH A MINIMUM OF DISMANTLING AND WITHOUT REQUIRING ADDITIONAL SUPPORTS AFTER THESE ITEMS ARE REMOVED.
- L. MISCELLANEOUS DRAINS, VENTS, RELIEFS, AND OVERFLOWS FROM TANKS, EQUIPMENT, PIPING, RELIEF VALVES, PUMPS, ETC., SHALL BE RUN TO THE NEAREST OPEN SIGHT DRAIN OR ROOF DRAIN. PROVIDE DRAIN VALVES WHENEVER REQUIRED FOR COMPLETE DRAINAGE OF PIPING, INCLUDING THE SYSTEM SIDE OF ALL PUMPS.
- M. INSTALL AIR VENTS IN CONDENSER, CHILLED AND HOT WATER PIPING AT ALL HIGH POINTS.

9. INSULATION

- A. PIPE INSULATION SHALL BE HEAVY DENSITY FIBERGLASS SECTIONAL PIPE INSULATION WITH A MAXIMUM K FACTOR OF 0.23 AT 15 DEGREES F MEAN TEMPERATURE WITH FACTORY APPLIED ALL SERVICE VAPOR BARRIER JACKET. DENSITY SHALL BE NOT LESS THAN 3 LBS. PER CU. FT.
- B. INSULATE ALL HOT/CHILLED WATER PIPING WITH 1-1/2" FIBERGLASS INSULATION WITH VAPOR BARRIER.

10. SHOP DRAWINGS

- A. PRIOR TO ISSUING SHOP DRAWING SUBMITTALS FOR THE ENGINEER'S REVIEW, THE CONTRACTOR SHALL BE RESPONSIBLE TO REVIEW ALL OF THE SUBMITTAL DATA. THE CONTRACTOR SHALL STAMP EACH SHOP DRAWING CERTIFYING THAT THE CONTRACTOR'S REVIEW HAS BEEN COMPLETED AND THAT COORDINATION HAS BEEN ESTABLISHED.
- B. THE CONTRACTOR SHALL BE RESPONSIBLE TO COORDINATE HIS WORK WITH THE WORK OF ALL OTHER TRADES. ALL SHOP DRAWINGS SHALL ILLUSTRATE THAT COORDINATION HAS BEEN ESTABLISHED. FOR SHEETMETAL, PIPING AND EQUIPMENT LAYOUTS COMPOSITE DRAWINGS SHALL BE SUBMITTED. FIELD RELATED CONFLICTS SHALL BE RESOLVED BY THIS CONTRACTOR.
- C. SUBMIT SHOP DRAWINGS (PROVIDE A MINIMUM OF FIVE COPIES TO ARCHITECT FOR ENGINEERS APPROVAL) COVERING THE FOLLOWING ITEMS:
1. DUCTWORK.
 2. PIPING.
 3. PIPE HANGERS AND SUPPORTS.
 4. PIPE INSULATION.
 5. FAN COIL UNITS.
 6. FANS.
 7. CONTROLS.
 8. AIR/HYDRONIC BALANCING REPORT.
- D. THE ENGINEER'S SHOP DRAWING APPROVAL SHALL NOT RELIEVE THE CONTRACTOR OF HIS RESPONSIBILITY TO COMPLY WITH ALL OF THE INFORMATION INDICATED IN THE CONTRACT DOCUMENTS (I.E. PLANS, SCHEDULES, DETAILS, NOTES AND SPECIFICATIONS ETC.).



II. TESTS AND BALANCING

- A. THE WORK OF THIS CONTRACTOR SHALL INCLUDE THE FURNISHING OF ALL TESTING INSTRUMENTS, GAUGES AND OTHER EQUIPMENT REQUIRED FOR NECESSARY TESTS, REQUIRED BY LAW RULES AND REGULATIONS AND AS SPECIFIED.
- B. NO VISIBLE LEAKS, LOSSES IN PRESSURE, OR INCREASE IN VACUUM SHALL OCCUR DURING TEST PERIOD.
- C. PROVIDE ALL OTHER TESTS REQUIRED BY BUILDING DEPARTMENT, FIRE DEPARTMENT AND ALL OTHER PUBLIC AGENCIES HAVING JURISDICTION.
- D. TESTS SHALL BE PERFORMED IN THE PRESENCE AND TO THE SATISFACTION OF THE ARCHITECT AND SUCH OTHER PARTIES AS MAY HAVE LEGAL JURISDICTION.
- E. OPERATE THE INSTALLATION AFTER COMPLETION FOR PERIOD NECESSARY TO MAKE ALL REQUIRED ADJUSTMENTS FOR AUTOMATIC CONTROLS, AIR OUTLETS AND FANS, UNTIL ALL PERFORMANCE CHARACTERISTICS ARE MET.
- F. ENGAGE THE SERVICES OF APPROVED INDEPENDENT AIR AND HYDRONIC BALANCING COMPANY TO BALANCE THE SYSTEM AND ISSUE AN AIR AND HYDRONIC BALANCING REPORT FOR ENGINEER'S APPROVAL. THE INDEPENDENT BALANCING COMPANY SHALL BE SUBJECT TO THE ENGINEER'S APPROVAL. THE TEST SHALL BE PERFORMED BY A PERSON HAVING A MINIMUM OF 5 YEARS EXPERIENCE IN TESTING AND BALANCING AIR AND HYDRONIC SYSTEMS.
- G. UPON COMPLETION OF THE INSTALLATION, THE AIR AND HYDRONIC BALANCE AND TESTING, SUBCONTRACTOR SHALL MAKE THE NECESSARY ADJUSTMENTS TO BALANCE THE SYSTEM, PROVIDE ANY EXTRA MANUAL VOLUME DAMPERS REQUIRED FOR PROPER AIR BALANCE.
- H. AT THE COMPLETION OF THE TEST, THE CONTRACTOR SHALL FURNISH THE ARCHITECT SEVEN (7) COPIES OF THE FINAL TEST REPORT.


12. GUARANTEE

- A. THE CONTRACTOR GUARANTEES BY HIS ACCEPTANCE OF THE CONTRACT THAT ALL WORK INSTALLED WILL BE FREE FROM ANY AND ALL DEFECTS FOR A PERIOD OF ONE YEAR FROM DATE OF COMPLETION AND ACCEPTANCE OF WORK.

HVAC SYMBOLS FOR ALTERATION WORK



NOTE: HANGERS MUST NOT DEFORM DUCT SHAPE.



METHOD OF HANGING ROUND DUCTWORK (N.T.S.)


DUCT DIAMETER	ROD DIAMETER	STRAP	WIRE DIAMETER	MAXIMUM SPACING
UP TO 10"	1/4"	1" X 22 ga.	ONE (1) 12 ga.	12'-0" O.C.
11" TO 18"	1/4"	1" X 22 ga.	THO (2) 12 ga. ONE (1) 8 ga.	12'-0" O.C.
18" TO 24"	1/4"	1" X 22 ga.	THO (2) 10 ga.	12'-0" O.C.
25" TO 36"	3/8"	1" X 20 ga.	THO (2) 8 ga.	12'-0" O.C.
37" TO 50"	(2) 3/8"	THO (2) 1" X 20 ga.	-	12'-0" O.C.
51" TO 60"	(2) 3/8"	THO (2) 1" X 18 ga.	-	12'-0" O.C.
61" TO 84"	(2) 3/8"	THO (2) 1" X 16 ga.	-	12'-0" O.C.

PIPING INSULATION NOTE:
CONTRACTOR SHALL INSPECT ALL EXISTING HOT/CHILLED WATER PIPING INSULATION THROUGHOUT THE BUILDING, INCLUDING CRAWL SPACE AND REPAIR OR REPLACE INSULATION AS REQUIRED.

Revisions

Date	Issue	Description
06-03-15	1	ISSUED FOR CONSTRUCTION
11-16-15	2	REVISED PER NUDCA ELECTRONIC STAMP

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA

955 Lincoln Ave.
Glen Rock, New Jersey
07452
t: 201.857.3998
f: 201.857.3994

2801 Dupont Drive-Suite 150
Irvine, California
92612
t: 714.424.0001
f: 714.424.0004

www.linwoodengineering.com

Project

INTERIOR RENOVATIONS
AT THE
SCIENCE - H RESIDENCE

RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client

RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

SNS Architects & Engineers, PC

1 PARAGON DRIVE . MONTVALE . NEW JERSEY . 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

- Fay W. Logan, AIA ☐
- John M. Lignos, AIA ☐
- Lorin J. Sonenshine, AIA ☐
- Steven Napolitano, PE ☐

Michael T. Davina, P.E.
NJ #48654
CT #0025779

Robert J. Hatch, P.E.
AR #13868
CA #E16118
CT #13318
FL #69560
MA #48516
NJ #35419
NY #019975
NY #56608
PA #036014-E

Cert./Lic. No.		Scale	AS NOTED
Drawn By	PS/Cadd	Checked By	MD
Dwg. Title			

HVAC NOTES, DETAILS AND SYMBOLS

Work Order No. Dwg. No.

4698H MO01