



NOTE:
ALL FIRE PROTECTION SYSTEM DEVICES AND PIPING SHOWN ARE DIAGRAMMATICAL AND ARE FOR REFERENCE ONLY. CONTRACTOR IS RESPONSIBLE TO FIELD VERIFY EXISTING CONDITIONS, INCLUDING BUT NOT LIMITED TO, NUMBER OF SPRINKLER HEADS, PIPE SIZES, DEVICE LOCATIONS AND ASSOCIATED CONTROLS. CONTRACTOR SHALL DESIGN AND INSTALL A NEW FIRE PROTECTION SYSTEM AS PER REQUIREMENTS OF NFPA 13 AND AUTHORITY HAVING JURISDICTION FOR THIS TYPE OF BUILDING CLASSIFICATION (R-2). CONTRACTOR SHALL PERFORM WATER FLOW TESTS, PROVIDE SIGNED AND SEALED HYDRAULIC CALCULATIONS AND FIRE PROTECTION PLANS, ALONG WITH FIRE PROTECTION EQUIPMENT SHOP DRAWINGS, TO THE ARCHITECT/ENGINEER FOR REVIEW AND SUBMISSION TO NJ DCA.

CRAWL SPACE FIRE PROTECTION PLAN
SCALE: 1/8"=1'-0"




FIRST FLOOR FIRE PROTECTION PLAN
SCALE: 1/8"=1'-0"



SECOND FLOOR FIRE PROTECTION PLAN
SCALE: 1/8"=1'-0"

Revisions		
Date	Issue	Description
06-03-15	1	ISSUED FOR CONSTRUCTION
11-16-15	2	REVISED PER NJDOA ELECTRONIC STAMP

Key Plan



Consultants

LINWOOD ENGINEERING ASSOCIATES, P.A.

CONSULTING MECHANICAL & ELECTRICAL ENGINEERS

LEA

955 Lincoln Ave.
Glen Rock, New Jersey 07452
t: 201.857.3998
f: 201.857.3984
www.linwoodengineering.com

2301 Dupont Drive-Suite 150
Irvine, California 92612
t: 714.424.0001
f: 714.424.0004

Project

INTERIOR RENOVATIONS
AT THE
SCIENCE - H RESIDENCE



RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

Client




RAMAPO COLLEGE
OF NEW JERSEY
505 Ramapo Valley Road
Mahwah, New Jersey 07430-1680

SNS

Architects & Engineers, PC

1 PARAGON DRIVE . MONTVALE . NEW JERSEY . 07645
tel: 201.573.1767 fax: 201.573.0808 www.sns-arch-eng.com

Fay W. Logan, AIA	○
John M. Lignos, AIA	○
Lorin J. Sonenshine, AIA	○
Steven Napolitano, PE	○



Michael T. Davina, P.E. NJ #48654 CT #0025779	Robert J. Hatch, P.E. AR #13868 CA #E16118 CT #15318 FL #69560 MA #48516 NJ #35419 NY #019975 PA #036014-E
--	---

Cert./Lic. No.		
Date	02-03-15	Scale AS NOTED
Drawn By	PS/Cadd	Checked By MD
Dwg. Title	CRAWL SPACE, FIRST & SECOND FLOOR FIRE PROTECTION PLANS	

Work Order No. 4698H Dwg. No. FP100