





1. ALL MODEL NUMBERS LISTED ARE FOR UNISTRUT. METAL FRAMING SHALL BE PRODUCTS OF UNISTRUT, B-LINE, KINDORF, GS METALS OR APPROVED EQUAL.
2. METAL CHANNEL SHALL BE 1/8" x 1/2" x 5/8" x 12 GAGE, WITH AN ELECTRO-DEPOSITION ACRYLIC COATING. CHANNEL SHALL BE EQUAL TO UNISTRUT P1000 SERIES.
3. ALL BOLTS AND CHANNEL NUTS SHALL BE 1/2"-13 THREAD. BOLTS SHALL BE HEX HEAD CAP SCREWS. CHANNEL NUTS SHALL BE EQUAL TO P1010 (NUT W/SPRING).
4. P1726 FITTINGS SHALL BE SECURED WITH 4 BOLTS EACH.
5. P2072A SO FITTINGS SHALL BE SECURED TO CHANNEL WITH TWO BOLTS.



6. UNISTRUT AT WALLS SHALL BE SECURED TO WALL WITH TOGGE BOLTS. INSTALL 1-1/4" FENDER WASHER BETWEEN UNISTRUT AND WALL.
7. PANEL SHALL BE SECURED TO CHANNEL WITH 4 BOLTS, TWO PER SIDE.
8. ADJUST WIDTH OF SUPPORTS TO MATCH MOUNTING HOLES IN PANEL BACKBOX.
9. P-1048 FITTINGS SHALL BE SECURED TO HORIZONTAL CHANNEL.




1. CONTRACTOR SHALL COORDINATE CONTROL WIRING WITH GENERATOR MANUFACTURER(S).



- **ARCHITECT:**
Mitchell/Giurgola Architects, LLP
630 Ninth Avenue, Suite 711
New York, New York 10036
212 663 4000
- **MEP ENGINEER:**
Joseph R. Loring & Associates, Inc.
21 Pennsylvania Plaza
New York, NY 10001
212 563 7400
- **STRUCTURAL ENGINEER:**
Ysrael A Seinku PC
228 East 45th Street 2nd Floor
New York, NY 10017
212 687 2233

- LANDSCAPE ARCHITECT:
Dirtworks, PC
200 Park Avenue South
New York, NY 10003
212 529 2263
- SITE CIVIL ENGINEER:
Langan Engineering
619 River Drive Center 1
Elmwood Park, NJ 07407-1338
201 794 6900
- AV CONSULTANT
Cerami & Associates
404 Fifth Avenue
New York, NY 10018
212 370 1776



Nº	DATE	COMMENTS
ISSUE/REVISION		

ALL DIMENSIONS AND EXISTING CONDITIONS SHALL BE CHECKED AND VERIFIED BY THE CONTRACTOR BEFORE PROCEEDING WITH THE WORK.

Submission:

CONSTRUCTION DOCUMENTS

Submission:

CONSTRUCTION DOCUMENTS

PROJECT Nº: 102700	DATE: 6/8/12
RCNJ PROJ. Nº: 08-240C	SCALE: NONE

PROJECT Nº: 102700	DATE: 6/8/12
RCNJ PROJ. Nº: 08-240C	SCALE: NONE

EG.02G